Installation Data Sheet - Screw Blower Series: CBS.2 Document Number: TI.BIDS-034 Version: 1.3 Revision Date: 04/24/2023						
Package Model	CBS 121 SFC (L & M	l)				
Electrical Data		•				
Horsepower	10	15	20	25	30	
Voltage (3ph/60Hz)	460	460	460	460	460	
Short Circuit Current Rating (SCCR) [kA] 460V/3ph/60Hz	50	50	50	50	50	
Package FLA +/- 10%	17.1	23.5	28.6	33.5	41.5	
Disconnect Fuse [Amp]	20	30	35	40	50	
Recommended Wire Size (75°C or higher) [AWG]	1 x 4 x 8	1 x 4 x 8	1 x 4 x 8	1 x 4 x 6	1 x 4 x 4	
Motor Data						
Insulation Class	F	F	F	F	F	
Enclosure Type	TEFC	TEFC	TEFC	TEFC	TEFC	
Туре	SynRM (IES2)	SynRM (IES2)	SynRM (IES2)	SynRM (IES2)	SynRM (IES2)	
Notes: 1. Time delay (dual element) fuse; Class $J \le 600A$ (e.g. AJT) 2. Fuse and wire sizes determined in accordance to NEC 240 3. Breaker should be suitable for a heavy duty starting load a 4. SFC Units come standard at 460 volts. 5. Ground wire size should be equal to conductor size. <b>SFC Operating Modes</b> <i>External Speed Control</i> The speed of the drive motor is controlled via an externally-supplied design.	0.6, 430.52 and table nd of inverse time de	elay design that com	plies to regulations o			
Fixed Speed The speed of the drive motor is controlled by an adjustable value b Pressure Regulation When machine runs in pressure regulation mode, the frequency co speed of the drive motor. The variation in speed determines the air as the unit is maintained within the control range of the machine (V	onverter compensates delivery of the machir	for deviations between	the set point pressure	and the actual pressu		

Oil System Data						
Drive End Capacity [qt.]		0.97				
Gear End Capacity [qt.]	1.11					
Oil Type (Synthetic)	G-680					
Working Pressure						
CBS 121 L SFC pr	Continued working pressures below 2.2 psig are not permitted					
CBS 121 M SFC pr	Continued working pressures below 4.4 psig are not permitted					
Package Connections						
HP	10	15	20	25	30	
Width [in.]	43 5/8	43 5/8	43 5/8	43 5/8	43 5/8	
Depth [in.]	53 7/8	53 7/8	53 7/8	53 7/8	53 7/8	
Height [in.]	66 5/8	66 5/8	66 5/8	66 5/8	66 5/8	
Floor [sq.ft.]	16 1/3	16 1/3	16 1/3	16 1/3	16 1/3	
Weight [lb.]	1338	1338	1371	1371	1374	
Connection Size [in.]	3	3	3	3	3	
Type [inlet (optional) and outlet]	Pipe	Pipe	Pipe	Pipe	Pipe	

	F	Ξ	- 2	
COMP	RES	SO	RS	ß

## Installation Data Sheet - Screw Blower

Series: CBS.2

Document Number: TI.BIDS-034

Version: 1.3

Revision Date: 04/24/2023

Package Model	CBS 121 SFC (L & M)
General Information	
Floating Relay Contacts	Ambient and Intake Conditions
Contacts:- X12:1 and 2Operation- X12:3 and 4Ready for operation- X12:5 and 6Group Alarm- X12:7 and 8Group Warning	Permissible ambient temperature [°F]* 32 - +113   Permissible intake temperature [°F]* +5 - +113   ion Relative humidity [%] 0 - 80   Maximum elevation [ft.asl]* 3280   *contact Kaeser about deviations in temperature or alititude alitical
Remote On/Off	External Alarm
Contacts (not floating): powered 24 VDC -X15: 5 and 6 Function: - from open to closed: Machine switches on - from closed to open: Machine switches off	Contacts (not floating): powered 24 VDC DI: 1.08 Function: - the machine will switch off in the event of this external fault
Ventilation of Blower Room	
Air Inlet Opening	2.3 sq. ft
Cooling Fan Capacity (forced ventilation)	1350 cfm
ax Heat Rejection 16,392 BTU/HR	
Ventilation values based on 440cfm @ 15 psig $\Delta P$ , 30Hp and an	nbient inlet. Max. room temp. = 113°F and cooling air temp = 100°F. Discharge piping length = 5ft.
Model shown for reference only Actual duct size may vary with installation	Recommended machine placement and dimensions:
1 Exhaust Fan	A Left side clearance = 3.9
2 Ventilation Inlet Air Opening	
X Cross direction	
	C Right side clearance = 3.9
Y Longitudinal direction	D Back clearance = 39.4 E Height clearance = 31.5
A	E Height clearance = 31.5
The foundation must be firm and capable of bearing the	Foundation in the cross direction (X) must be level, inclination max. 0.8°
weight of the machine.	Foundation in the longitudinal direction (Y) must be level, inclination max. 2.0°
	It is recommended to extract the exhaust air from the upper third of the room as this is where the heat collects. The room ventilation openings should be arranged that the current of cooling air flowing through the room passes over the blower inlet and exhaust ports and, if possible, should leave no stagnant air in the room. (A thermal short circuit must be avoided, i.e. discharged cooling air must not find its way to the cooling air inlet.) The blower must not be positioned so near to a wall that the inflow of cooling air is obstructed. Pipework should be insulated against heat emission. If the blower station is located in the middle of a large hall its exhaust air can be extracted by means of a duct positioned above the exhaust port (illustrated in broken lines).